

# Energy performance certificate (EPC)

## Certificate contents

- Energy rating and score
- Breakdown of property's energy performance
- How this affects your energy bills
- Impact on the environment
- Changes you could make
- Who to contact about this certificate
- Other certificates for this property

## Share this certificate

- Email
- Copy link to clipboard
- Print


1 Rocklands HILLSBOROUGH BT26 6NU		Energy rating <b>D</b>
Valid until 15 February 2034	Certificate number 3400-5960-0822-6390-3243	

Property type	Detached house
Total floor area	131 square metres

## Energy rating and score

This property's energy rating is D. It has the potential to be D.

[See how to improve this property's energy efficiency.](#)



The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

- For properties in Northern Ireland:
- the average energy rating is D
  - the average energy score is 60

## Breakdown of property's energy performance

### Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Cavity wall, filled cavity	Good
Roof	Pitched, 250 mm loft insulation	Good
Window	Fully double glazed	Average
Main heating	Boiler and radiators, oil	Average
Main heating control	Programmer, room thermostat and TRVs	Good
Hot water	From main system	Average
Lighting	Low energy lighting in 36% of fixed outlets	Average
Floor	Suspended, no insulation (assumed)	N/A
Secondary heating	Room heaters, coal	N/A

### Primary energy use

The primary energy use for this property per year is 210 kilowatt hours per square metre (kWh/m2).

[About primary energy use](#)

## How this affects your energy bills

An average household would need to spend **£1,938 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £362 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2024** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

## Impact on the environment

This property's environmental impact rating is E. It has the potential to be E.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

### Carbon emissions

An average household produces	6 tonnes of CO2
This property produces	7.7 tonnes of CO2
This property's potential production	6.3 tonnes of CO2

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

## Changes you could make

[Do I need to follow these steps in order?](#)

### Step 1: Low energy lighting

Typical installation cost	£35
Typical yearly saving	£82
Potential rating after completing step 1	59 D

### Step 2: Floor insulation (suspended floor)

Typical installation cost	£800 - £1,200
Typical yearly saving	£228
Potential rating after completing steps 1 and 2	65 D

### Step 3: High performance external doors

Typical installation cost	£2,000
Typical yearly saving	£51
Potential rating after completing steps 1 to 3	66 D

### Step 4: Solar water heating

Typical installation cost	£4,000 - £6,000
Typical yearly saving	£76
Potential rating after completing steps 1 to 4	68 D

### Step 5: Solar photovoltaic panels, 2.5 kWp

Typical installation cost	£3,500 - £5,500
Typical yearly saving	£531
Potential rating after completing steps 1 to 5	76 C

### Step 6: Wind turbine

Typical installation cost	£15,000 - £25,000
Typical yearly saving	£1,111
Potential rating after completing steps 1 to 6	91 B

### Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme](#). This will help you buy a more efficient, low carbon heating system for this property.

## Who to contact about this certificate

### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Andrew McCallin
Telephone	02890 430911
Email	<a href="mailto:andrew.mccallin@aol.co.uk">andrew.mccallin@aol.co.uk</a>

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/005216
Telephone	01455 883 250
Email	<a href="mailto:enquiries@elmhurstenergy.co.uk">enquiries@elmhurstenergy.co.uk</a>

### About this assessment

Assessor's declaration	No related party
Date of assessment	16 February 2024
Date of certificate	16 February 2024
Type of assessment	<a href="#">RdSAP</a>

## Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at [duhc.digital-services@levellingup.gov.uk](mailto:duhc.digital-services@levellingup.gov.uk) or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related certificates for this property.