

Energy performance certificate (EPC)

| | | |
|--|--|---|
| 11, Sunwich Street BELFAST BT6 8JT | Energy rating <h1 style="font-size: 2em; margin: 0;">F</h1> | Valid until: 15 June 2026 <hr/> Certificate number: 9105-4866-6929-1690-1663 |
|--|--|---|

Property type Mid-terrace house

Total floor area 83 square metres

Energy efficiency rating for this property

This property's current energy rating is F. It has the potential to be E.

[See how to improve this property's energy performance.](#)

| Score | Energy rating | Current | Potential |
|-------|---------------|---------|-----------|
| 92+ | A | | |
| 81-91 | B | | |
| 69-80 | C | | |
| 55-68 | D | | |
| 39-54 | E | | 54 E |
| 21-38 | F | 33 F | |
| 1-20 | G | | |

The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

For properties in Northern Ireland:

the average energy rating is D
 the average energy score is 60

Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says “assumed”, it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

| Feature | Description | Rating |
|----------------------|--|-----------|
| Wall | Solid brick, as built, no insulation (assumed) | Very poor |
| Wall | Cavity wall, as built, insulated (assumed) | Good |
| Roof | Roof room(s), no insulation (assumed) | Very poor |
| Window | Fully double glazed | Average |
| Main heating | Boiler and radiators, oil | Average |
| Main heating control | Programmer, TRVs and bypass | Average |
| Hot water | From main system, no cylinder thermostat | Poor |
| Lighting | No low energy lighting | Very poor |
| Floor | Suspended, no insulation (assumed) | N/A |
| Floor | Solid, no insulation (assumed) | N/A |
| Secondary heating | Room heaters, electric | N/A |

Primary energy use

The primary energy use for this property per year is 365 kilowatt hours per square metre (kWh/m²).

Environmental impact of this property

This property produces 7.4 tonnes of CO₂

This property's current environmental impact rating is F. It has the potential to be E.

This property's potential production 5.0 tonnes of CO₂

Properties are rated in a scale from A to G based on how much carbon dioxide (CO₂) they produce.

By making the [recommended changes](#), you could reduce this property's CO₂ emissions by 2.4 tonnes per year. This will help to protect the environment.

Properties with an A rating produce less CO₂ than G rated properties.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

An average household produces 6 tonnes of CO₂

Improve this property's energy performance

By following our step by step recommendations you could reduce this property's energy use and potentially save money.

Carrying out these changes in order will improve the property's energy rating and score from F (33) to E (54).

| Step | Typical installation cost | Typical yearly saving |
|---|---------------------------|-----------------------|
| 1. Increase hot water cylinder insulation | £15 - £30 | £30 |
| 2. Low energy lighting | £90 | £45 |
| 3. Room-in-roof insulation | £1,500 - £2,700 | £365 |
| 4. Heat recovery system for mixer showers | £585 - £725 | £21 |
| 5. Solar water heating | £4,000 - £6,000 | £71 |
| 6. Internal or external wall insulation | £4,000 - £14,000 | £86 |
| 7. Solar photovoltaic panels | £5,000 - £8,000 | £266 |

Paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/guidance/check-if-you-may-be-eligible-for-the-boiler-upgrade-scheme-from-april-2022\)](https://www.gov.uk/guidance/check-if-you-may-be-eligible-for-the-boiler-upgrade-scheme-from-april-2022). This will help you buy a more efficient, low carbon heating system for this property.

[Find energy grants and ways to save energy in your home \(https://www.gov.uk/improve-energy-efficiency\)](https://www.gov.uk/improve-energy-efficiency).

Estimated energy use and potential savings

Estimated yearly energy cost for this property £1419

Potential saving £460

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

The potential saving shows how much money you could save if you [complete each recommended step in order](#).

Heating use in this property

Heating a property usually makes up the majority of energy costs.

Potential energy savings by installing insulation

The assessor did not find any opportunities to save energy by installing insulation in this property.

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

| | |
|-----------------|--|
| Assessor's name | Abigail Boyd |
| Telephone | 07927 041475 |
| Email | abienergycerts@gmail.com |

Accreditation scheme contact details

| | |
|----------------------|--|
| Accreditation scheme | Elmhurst Energy Systems Ltd |
| Assessor ID | EES/008135 |
| Telephone | 01455 883 250 |
| Email | enquiries@elmhurstenergy.co.uk |

Assessment details

| | |
|------------------------|-----------------------|
| Assessor's declaration | No related party |
| Date of assessment | 16 June 2016 |
| Date of certificate | 16 June 2016 |
| Type of assessment | RdSAP |
