

# Energy performance certificate (EPC)

396 BELMONT ROAD BELFAST BT4 2NH		Energy rating <b>A</b>
Valid until 14 February 2031	Certificate number <b>0552-3815-1122-2199-6675</b>	


**Property type** Detached house

**Total floor area** 253 square metres

## Energy efficiency rating for this property

This property's current energy rating is A. It has the potential to be A.

[See how to improve this property's energy performance.](#)



The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

The average energy rating and score for a property in Northern Ireland are D (60).

### Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Walls	Average thermal transmittance 0.20 W/m²K	Very good
Roof	Average thermal transmittance 0.14 W/m²K	Very good

Feature	Description	Rating
Floor	Average thermal transmittance 0.10 W/m <sup>2</sup> K	Very good
Windows	High performance glazing	Very good
Main heating	Air source heat pump, electric	Very good
Main heating control	Time and temperature zone control	Very good
Hot water	From main system	Very good
Lighting	Low energy lighting in 94.6% of fixed outlets	Very good
Air tightness	Air permeability 4.5 m <sup>3</sup> /h.m <sup>2</sup> (as tested)	Good
Secondary heating	Room heaters, dual fuel (mineral and wood)	N/A

## Primary energy use

The primary energy use for this property per year is 65 kilowatt hours per square metre (kWh/m<sup>2</sup>).

► [What is primary energy use?](#)

### Environmental impact of this property

One of the biggest contributors to climate change is carbon dioxide (CO<sub>2</sub>). The energy used for heating, lighting and power in our homes produces over a quarter of the UK's CO<sub>2</sub> emissions.

<b>An average household produces</b>	6 tonnes of CO <sub>2</sub>
<b>This property produces</b>	2.9 tonnes of CO <sub>2</sub>
<b>This property's potential production</b>	2.9 tonnes of CO <sub>2</sub>

By making the [recommended changes](#), you could reduce this property's CO<sub>2</sub> emissions by 0.0 tonnes per year. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

## How to improve this property's energy performance

Making any of the recommended changes will improve this property's energy efficiency.

If you make all of the recommended changes, this will improve the property's energy rating and score from A (92) to A (92).

▶ [What is an energy rating?](#)

Potential energy  
rating

A

## Recommendation 1: Solar photovoltaic panels, 2.5 kWp

Solar photovoltaic panels

**Typical installation cost**

£11,000 - £20,000

**Typical yearly saving**

£258

**Potential rating after carrying out recommendation 1**

95 | A

## Paying for energy improvements

[Find energy grants and ways to save energy in your home. \(https://www.gov.uk/improve-energy-efficiency\)](https://www.gov.uk/improve-energy-efficiency)

**Estimated energy use and potential savings**

**Estimated yearly energy cost for this property**

£643

**Potential saving**

£0

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

The estimated saving is based on making all of the recommendations in [how to improve this property's energy performance](#).

## Heating use in this property

Heating a property usually makes up the majority of energy costs.

## Potential energy savings by installing insulation

The assessor did not find any opportunities to save energy by installing insulation in this property.

## Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

## Assessor contact details

**Assessor's name** Gareth Chambers

**Telephone** 0845 6211111

**Email** [info@stroma.com](mailto:info@stroma.com)

## Accreditation scheme contact details

**Accreditation scheme** Stroma Certification Ltd

**Assessor ID** STRO014058

**Telephone** 0330 124 9660

**Email** [certification@stroma.com](mailto:certification@stroma.com)

## Assessment details

**Assessor's declaration** No related party

**Date of assessment** 15 February 2021

**Date of certificate** 15 February 2021

**Type of assessment** ▶ [SAP](#)

### Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at [mhclg.digital-services@communities.gov.uk](mailto:mhclg.digital-services@communities.gov.uk), or call our helpdesk on 020 3829 0748.

There are no related certificates for this property.