Energy performance certificate (EPC)

76, Drumnabreeze Road Magheralin CRAIGAVON BT67 0RH	Energy rating **C**	Valid until:	**17 March 2030**
		Certificate number:	**9839-1096-0397-7800-5224**

Property type	Detached house
Total floor area	455 square metres

Energy rating and score

This property's energy rating is C. It has the potential to be C.

See how to improve this property's energy efficiency.



The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in Northern Ireland:

the average energy rating is D
the average energy score is 60

Breakdown of property’s energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property’s age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Walls	Average thermal transmittance 0.25 W/mÂ²K	Very good
Roof	Average thermal transmittance 0.14 W/mÂ²K	Very good
Floor	Average thermal transmittance 0.14 W/mÂ²K	Very good
Windows	High performance glazing	Very good
Main heating	Boiler and underfloor heating, oil	Average
Main heating control	Time and temperature zone control	Very good
Hot water	From main system	Good
Lighting	Low energy lighting in all fixed outlets	Very good
Air tightness	Air permeability 4.1 mÂ³/h.mÂ² (as tested)	Good
Secondary heating	None	N/A

Primary energy use

The primary energy use for this property per year is 98 kilowatt hours per square metre (kWh/m2).

How this affects your energy bills

An average household would need to spend **£2,403 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £0 per year** if you complete the suggested steps for improving this property’s energy rating.

This is **based on average costs in 2020** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Impact on the environment

This property's environmental impact rating is C. It has the potential to be C.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

Carbon emissions

An average household produces	6 tonnes of CO2
This property produces	10.6 tonnes of CO2
This property's potential production	10.6 tonnes of CO2

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Steps you could take to save energy

Step	Typical installation cost	Typical yearly saving
1. Solar photovoltaic panels	£3,500 - £5,500	£248

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Nigel Cairns
Telephone	07887541427
Email	info@cairnsconsultingni.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd
Assessor's ID	STRO000259
Telephone	0330 124 9660
Email	certification@stroma.com

About this assessment

Assessor's declaration	No related party
Date of assessment	17 March 2020
Date of certificate	18 March 2020
Type of assessment	SAP